



EVPÜ[®]

NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0755

In compliance with *Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011* (the Construction products Regulation or CPR), this certificate applies to the construction product

Wall-mounted cabinet speaker DAL 165/6 EN, DAL 165/6 EN1

For specifications see Annex to this certificate

placed on the market under the name or trade mark of

Jagro Acoustic Solutions e.K.
Im Bieth 26, 69124 Heidelberg, Germany

and produced in the manufacturing plant

Jagro Acoustic Solutions e.K.
Im Bieth 26, 69124 Heidelberg, Germany

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 54-24: 2008

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on February 12th, 2021 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Nová Dubnica, February 12th, 2021

053917

EVPÜ a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, www.evpu.sk
Page 1 / 2 FCO 425-13 Rev.1




Michal Mišiak

Annex to Certificate No. 1293 - CPR – 0755 from February 12th, 2021

Technical specifications:

| | |
|--------------------------------|---|
| EN 54-24 degree: | Type A |
| Chassis-type: | 165mm full range 8Ω |
| Transformer: | 100V, 6/3/1.5/(0.75)W |
| Transformer impedance: | 1667Ω-6W, 3333Ω-3W, 6667Ω-1.5W, 13333Ω-0.75W |
| Sensitivity 1W/4m: | 79dB |
| SPL rated noise power: | 87dB |
| Coverage angel (0,5/1/2/4kHz): | 180/180, 180/180, 126/126, 60/60 |
| Dimensions: | Φ170x75mm |
| Material: | Powder-coated steel |
| Colour: | RAL 9010 matt |
| Weight: | 1.1kg |
| Connection: | 3-pole ceramic terminal (DAL 165/6 EN) 2-pole plastic pressure clamp (DAL 165/6 EN1) |

| Essential characteristics | Test specification | Harmonised technical specifications | Performance |
|---|---------------------------|-------------------------------------|-------------|
| Performance under fire conditions | cl. 4.2, 5.2 to 5.5 | EN 54-24:2008 | Pass |
| Operational reliability | cl. 4.3 to 4.5, 5.6, 5.18 | EN 54-24:2008 | Pass |
| Durability of operational reliability: temperature resistance | cl. 5.7, 5.8=N/A, 5.9 | EN 54-24:2008 | Pass |
| Durability of operational reliability: humidity resistance | cl. 5.10, 5.11, 5.12=N/A | EN 54-24:2008 | Pass |
| Durability of operational reliability: corrosion resistance | cl. 5.13 | EN 54-24:2008 | Pass |
| Durability of operational reliability: shock and vibration resistance | cl. 5.14 to 5.17 | EN 54-24:2008 | Pass |



Nová Dubnica, February 12th, 2021

Michal Mišík
Michal Mišík