



NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 - CPR - 0758

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Wall/ceiling projector DAW-K 130/10 EN, DAW-K 130/10 EN1

For specifications see Annex to this certificate

placed on the market under the name or trade mark of

Jagro Acoustic Solutions e.K. Im Bieth 26, 69124 Heidelberg, Germany

and produced in the manufacturing plant

Jagro Acoustic Solutions e.K. Im Bieth 26, 69124 Heidelberg, Germany

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 54-24: 2008

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on February 12th, 2021 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

E/S E/S NOVA

Michal Mišiak

Nová Dubnica, February 12th, 2021

053922

EVPÚ a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, <u>www.evpu.sk</u> Page 1 / 2 FCO 425-13 Rev.1

Annex to Certificate No. 1293 - CPR - 0758 from February 12th, 2021

Technical specifications:

EN 54-24 degree: Type B

Chassis-type: 130 mm full range 8Ω Transformer: 100 V, 10/6/3/1.5 W

Transformer impedance: 1000Ω -10W, 1667Ω -6W, 3333Ω -3W, 6667Ω -1.5W

Sensitivity 1W/4m: 77dB SPL rated noise power: 88dB

Coverage angel (0,5/1/2/4kHz): 360/360, 340/340, 132/132, 55/55

Dimensions: Φ137x200mm Material: ABS high impact

Colour: white Weight: 1.5kg

Connection: 3-pole ceramic terminal (DAW-K 130/10 EN)

2-pole plastic pressure clamp (DAW-K 130/10 EN1)

Essential characteritics	Test specification	Harmonised technical specifications	Performance
Performance under fire conditions	cl. 4.2, 5.2 to 5.5	EN 54-24:2008	Pass
Operational reliability	cl. 4.3 to 4.5, 5.6, 5.18	EN 54-24:2008	Pass
Durability of operational reliability: temperature resistance	cl. 5.7, 5.8, 5.9	EN 54-24:2008	Pass
Durability of operational reliability: humidity resistance	cl. 5.10, 5.11, 5.12	EN 54-24:2008	Pass
Durability of operational reliability: corrosion resistance	cl. 5.13	EN 54-24:2008	Pass
Durability of operational reliability: shock and vibration resistance	cl. 5.14 to 5.17	EN 54-24:2008	Pass



Nová Dubnica, February 12th, 2021

Michal Mišiak